

		Iluminación	Tomacorrientes	Fuerza Motriz					Potencia Instalada		Potencia Simultánea	Intensidad Simultánea [A]			
		Cant.	Cant.	Cant.					[W]		[W]	R	S	T	
Tablero Principal - Energía Normal	TS1/PB	107	55	0					26531		13655	25	24	24	
	TS2/PB	0	0	1					9694		8725	16	16	16	
	TS3/PB	96	28	0					14195		6577	12	12	12	
	TS4/PB	0	0	1					9694		8725	16	16	16	
	TS5/PB	97	44	0					22855		10556	19	19	19	
	TS6/PB	0	0	1					9694		8725	16	16	16	
Tablero Principal - Energía de Emergencia y Reemplazo	TS1/PB	27	0	0					1080		713	1	0	3	
	TS2/PB	0	0	1					9694		8725	16	16	16	
	TS3/PB	38	0	0					1599		1049	2	2	1	
	TS4/PB	0	0	1					9694		8725	16	16	16	
	TS5/PB	51	0	0					2120		1399	2	3	2	
	TS6/PB	0	0	1					9694		8725	16	16	16	
	TS7/PB	0	0	1					2610		2349	4	4	4	
		Potencia Trifásica Total Instalada [W]							129.185,55	Potencia Trifásica Total Simultánea [W]				88.746,06	
Factor de crecimiento demanda (fcd) =		1,2	Potencia Trifásica Total Instalada c/fcd [W]							155.022,66	Potencia Trifásica Total Simultánea c/fcd [W]				106.495,27

PLANTA BAJA
POTENCIA TRIFÁSICA
TOTAL SIMULTÂNEA
89 KW